

Appendix H Regular Construction Noise Monitoring Results

Daytime Noise Monitoring Results at Station E-N12a (19 Hing Yan Street)

Date	Weather Condition	Noise Level for 30-min, dB(A) ⁺				Limit Level, dB(A)	Exceedance (Y/N)
		Time	L90	L10	Leq		
5-Jan-21	Fine	14:00	58.9	60.1	59.3	75	N
11-Jan-21	Cloudy	15:15	57.8	59.9	58.9	75	N
22-Jan-21	Sunny	15:00	58.9	60.9	59.7	75	N
28-Jan-21 ¹	-	-	-	-	-	75	N

Remark:

1. As the sewage sampling was tested positive for COVID-19 near the noise monitoring location at 19 Hing Yan Street (E-N12a). Therefore, the impact noise monitoring at this location will be provisionally suspended for 14 days. (From 27 January 2021 to 9 February 2021)



Daytime Noise Monitoring Results at Station E-N21a (Block B of Merit Industrial Centre)

Date	Weather Condition	Noise Level for 30-min, dB(A) [#]				Limit Level, dB(A)	Exceedance (Y/N)
		Time	L90	L10	Leq		
5-Jan-21	Fine	9:30	60.4	61.8	61.3	75	N
11-Jan-21	Cloudy	14:00	59.8	61.2	60.3	75	N
22-Jan-21	Sunny	10:00	60.4	61.8	60.7	75	N
28-Jan-21	Sunny	14:50	58.9	60.3	59.6	75	N

⁺ - Façade measurement.

[#] - A correction of +3dB(A) was made to the free field measurement.

^{*} - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school



This Drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent.