


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)
Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
02-Apr-25	9:00	Sunny	66.5	69.9	62.3	67.7	66.5 Measured ≤ Baseline
07-Apr-25	11:00	Fine	68.2	70.6	58.9	67.7	58.6
17-Apr-25	9:00	Sunny	66.8	69.6	62.9	67.7	66.8 Measured ≤ Baseline
22-Apr-25	9:00	Cloudy	67.2	69.8	63.4	67.7	67.2 Measured ≤ Baseline
29-Apr-25	14:40	Sunny	69.5	71.4	58.8	67.7	64.8

Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA20024	CINOTECH
	Date Apr-25	Appendix G	