


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
08-Jan-26	16:10	Sunny	66.1	68.8	60.3	67.7	66.1 Measured \leq Baseline
14-Jan-26	15:30	Sunny	64.0	66.7	54.2	67.7	64 Measured \leq Baseline
20-Jan-26	16:36	Fine	66.9	69.7	57.9	67.7	66.9 Measured \leq Baseline
26-Jan-26	15:17	Fine	65.3	68.0	57.5	67.7	65.3 Measured \leq Baseline

Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA20024	
	Date Jan-26	Appendix G	