


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)  
Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
04-Jun-25	15:00	Cloudy	65.9	69.3	59.7	67.7	65.9 Measured ≤ Baseline
10-Jun-25	9:00	Sunny	66.4	69.1	59.6	67.7	66.4 Measured ≤ Baseline
16-Jun-25	15:45	Cloudy	63.2	66.3	57.2	67.7	63.2 Measured ≤ Baseline
27-Jun-25	9:00	Cloudy	67.4	70.5	60.4	67.7	67.4 Measured ≤ Baseline

## Noise Levels



<b>Title</b> Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works  Graphical Presentation of Construction Noise Monitoring Results	<b>Scale</b> N.T.S	<b>Project</b> No. MA20024	<b>CINOTECH</b>
	<b>Date</b> Jun-25	<b>Appendix</b> G	