


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)
Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
03-Sep-25	15:25	Fine	65.7	67.9	60.3	67.7	65.7 Measured ≤ Baseline
09-Sep-25	14:30	Cloudy	66.3	68.7	62.4	67.7	66.3 Measured ≤ Baseline
15-Sep-25	16:00	Sunny	66.8	69.2	60.8	67.7	66.8 Measured ≤ Baseline
25-Sep-25	16:05	Cloudy	63.5	67.1	59.8	67.7	63.5 Measured ≤ Baseline
30-Sep-25	16:00	Fine	66.1	68.5	62.3	67.7	66 Measured ≤ Baseline

Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA20024	CINOTECH
	Date Sep-25	Appendix G	